


Blown Up Section of First Revised Permit Site Plan

permits
are req
or Plum
Structural Re
Zoning Rules

Sloped Loading Platform

26 Feet Noted as The Distance Between Facade and Property Line



No Dimensions Provided for Loading Berth Door but it's clear the opening is less than the required 12 feet